

CERTIFICATE OF COMPLIANCE

Certificate Number 20160909-E194810
Report Reference E194810-20080613
Issue Date 2016-JULY-26

Issued to: ROCKWELL AUTOMATION/ ALLEN-BRADLEY
1 ALLEN-BRADLEY DR
MAYFIELD HEIGHTS, OH 44124

This is to certify that representative samples of PROGRAMMABLE CONTROLLERS FOR USE IN HAZARDOUS LOCATIONS

See addendum pages for models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No. 213, Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA C22.2 No. 142, Process Control Equipment, Industrial Products
UL 1604, Electrical Equipment for use in Class I and II, Division 2, and Class III Hazardous (Classified) Locations
UL 508, Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160909-E194810
Report Reference E194810-20080613
Issue Date 2016-JULY-26

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Evaluated to ANSI/ISA, and CAN/CSA C22.2 No. 213-M1987

Programmable controllers, Models 1794-IF8IH, 1794-OF8IH


Programmable controllers: Analog input modules, Model 1769-IT6, 1769-OF8V, 1769-OF8C, 1769-OF4VI, 1769-OF4CI, 1769-IF4I, 1794-IF8IHNFX, 1756-IF8H, 1756-OF8H, 1756-IF16H

Programmable controller I/O module, Model 1769-IR6.

Programmable controllers: analog input/output modules, Models 1756-IF8IH, 1756-OF8IH, 1756-IF16HK, 1756-IF8HK, 1756-IF8IHK, 1756-OF8IHK, 1756-OF8HK, 1756-IF16IH

Evaluated to UL 1604, UL 508, CAN/CSA C22.2 No. 213 and CAN/CSA C22.2 No. 142

RTD/Resistance (Logic) module, Model 1746-NR8



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

