

EU Declaration of Conformity

<i>Product:</i>	Regional Circuit Breaker	
-----------------	---------------------------------	--

<i>Name and address of the manufacturer:</i>	<i>Name and address of the authorised representative:</i>	
Rockwell Automation, Inc.	Rockwell Automation B.V.	
1201 South 2nd Street	Rivium Promenade 160	
Milwaukee, WI 53204	2909 LM Capelle aan den IJssel	
U.S.A.	The Netherlands	

This declaration of conformity is issued under the sole responsibility of the manufacturer.

<i>Object of the declaration:</i>	Allen Bradley, 188-K Series	
	<i>(reference the attached list of catalogue numbers)</i>	

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

2006/95/EC & 2014/35/EU	Low Voltage Directive	(LVD)
------------------------------------	------------------------------	--------------


References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 60898-1:2003 + A1:2004 +	Electrical accessories – Circuit-breakers for overcurrent protection for	
A11:2005 + A13:2012	household and similar installations – Part 1: Circuit breakers for a.c.	
	operation	

Additional information:

<i>Year of CE Marking (LVD):</i>	2014
----------------------------------	-------------

Signed for and on behalf of the above named manufacturer:

<i>Place and date of issue:</i>	Milwaukee, WI USA	19-Feb-2016
<i>Name, function:</i>	Daniel L. Nachtigall, Technical Leader – Product Certification Engineering	
<i>Signature:</i>		

<i>Catalogue number</i>	<i>Series ¹</i>	<i>Description</i>
188-Kxxxx		<i>Regional circuit breakers per Nomenclature</i>

1) *If no series number is given, then all series are covered*

MODEL NOMENCLATURE:

188-K	-	1	C	020	-	N
1		2	3	4		6

1	Product Line 188-K – Regional circuit breakers
2	Designates Number of Poles 1 – 1 pole 2 – 2 pole 3 – 3 pole 4 – 4 pole
3	Designates Trip Code B – Trip Curve B C – Trip Curve C D – Trip Curve D
4	Designates Current Rating 005 – 0.5 A* 040 – 4 A* 160 – 16 A 500 – 50 A 010 – 1 A* 060 – 6 A 200 – 20 A 630 – 63 A 016 – 1.6 A* 080 – 8 A 250 – 25 A 020 – 2 A* 100 – 10 A 320 – 32A 030 – 3 A* 130 – 13A 400 – 40 A *C and D trip curves only
5	Designates Neutral Pole Blank – No neutral pole N – Neutral pole provided